



Producer Statement

NZ Ceiling and Drywall Supplies Limited

Collated Drywall Screws

August 2023

New Zealand Ceiling and Drywall Supplies collated drywall screws have been tested by SCION Research, Rotorua and achieved the following performance.

- BU wind = 83 (69 BU/m) as limited by the ultimate capacity.
1200 x 2.4 GIB standard board tested on concrete floor
- BU earthquake = 64 (54 BU/m) as limited by ultimate capacity.
1200 x 2.4 GIB standard board tested on concrete floor
- BU wind = 149 (124 BU/m) as limited by the ultimate capacity.
1200 x 2.4 GIB Braceline board one side walls as tested on concrete floor
- BU Earthquake = 126 (105BU/m) as limited by the ultimate load capacity.
GIB Braceline board one side walls as tested on concrete floor

Based on independent structural testing, New Zealand Ceiling & Drywall Supplies Limited warrants that when NZCDS 32mm x 6g drywall screws are substituted for GIB® Grabber® screws in GIB EzyBrace® systems the claimed structural bracing performance will not be compromised and meets the in-service structural bracing performance of the relevant GIB Ezybrace® system(s).

Limitation

This warranty is limited to structural bracing performance and does not extend to fire or noise control functionality.